

**Overview and Scrutiny (Performance and Growth) Panel – Questions requiring a response.**

<b>Minute No.</b>	<b>Item</b>	<b>Councillor</b>	<b>Question</b>	<b>Answer</b>
24/13	Finance Performance 2023/24 Quarter 4 Report	Cllr Jennings	Request for further details of the noted variance of higher than expected utilities costs at One Leisure.	That the extra utilities costs were as a result of the combined heat and power unit (CHP) not working at One Leisure St Ives in January and February 2024, this has increased use of electricity, the CHP was fixed at the end of February. Additional monitoring of the CHP units will be available from the new building management system contractor, which will help to reduce downtime in the future.
24/8	Corporate Plan Targets 2024/25	Cllr Cawley	PI22 – what is the work on weeds being undertaken?	Awaiting response.